DRAWING NUMBER

DRAWING NUMBER

DRAWING NUMBER

1/8" = 1' - 0"

1/4" = 1' - 0"

3/8" = 1' - 0"

1/2" = 1' - 0"

3/4" = 1' - 0"

1" = 1' - 0"

1-1/2" = 1' - 0"

3" = 1' - 0"

A.C. PUMP ROOM

ELEC. CLOS. #2

A.C. PUMP ROOM

TEL. CLOS. #1

ELEC. CLOS. #1

RELOCATE EXIST. ATD W/FD SEE DWG. M-2 FOR NEW LOCATION.

ATD

FD

BLANK OFF

REMOVE EXIST. AC-6 AND ALL ASSOCIATED WIRING, T-STAT, PIPING & CONDS. PUMP TOTAL COOLING CAPACITY TO BE REMOVED IS 30,000 BTU/HR.

AC-7

RELOCATE EXIST. AC-7 T-STAT SEE DWG. M-2 FOR NEW LOCATION

REMOVE EXIST. ATD

REMOVE EXIST. ATD

EXIST. ATD 25"x22" TO REMAIN (TYP. FOR 3)

REMOVE & RELOCATE EXIST. INDUCTION UNIT

REMOVE EXIST. 1 1/2 CAP INDUCT. UNIT & REPLACE WITH REMOVED EXIST FULL CAP. INDUCTION UNIT.

NOTE:
SEE PIPING CONNECTION DETAIL ON DWG. M-3 FOR REMOVAL & RECONNECTION OF THESE INDUCTION UNITS.

PLAN VIEW